

# K

## Soil Specifications

The revised regional Specification of Soils for Biotreatment or Bioretention Facilities, approved by the Regional Water Board on April 18, 2016, are provided on the following pages. Provision C.3.c.i.(2)(c)(ii) of the reissued MRP (Regional Water Board Order No. R2-2015-0049), dated November 19, 2015, allowed for the previous version of these specifications to be revised, subject to approval of the Regional Water Board's Executive Officer. Biotreatment facilities designed to meet Provision C.3 requirements must use biotreatment soil media that meet the minimum specifications set forth in the following pages. Alternative biotreatment mixes that achieve a long-term infiltration rate of 5 to 10 inches per hour, and are suitable for plant health, may be used in accordance with the requirements described in the specifications, under the heading "Verification of Alternative Bioretention Soil Mixes".

This appendix includes the following documents:

- Specification of Soils for Biotreatment or Bioretention Facilities
- Approval letter from the Regional Water Board Executive Officer
- Biotreatment Soil Mix Specification Verification Checklist
- Biotreatment Soil Mix Supplier List
- Biotreatment Soil Mix Supplier Certification Statement
- Bioretention Soil Installation Guidance

The documents included in this appendix may be downloaded from the Clean Water Program's website at:

[www.cleanwaterprogram.org](http://www.cleanwaterprogram.org) (click on "Resources," then "Development.")

## Specification of soils for Biotreatment or Bioretention Facilities

Soils for biotreatment or bioretention areas shall meet two objectives:

- Be sufficiently permeable to infiltrate runoff at a minimum rate of 5" per hour during the life of the facility, and
- Have sufficient moisture retention to support healthy vegetation.

Achieving both objectives with an engineered soil mix requires careful specification of soil gradations and a substantial component of organic material (typically compost).

Local soil products suppliers have expressed interest in developing 'brand-name' mixes that meet these specifications. At their sole discretion, municipal construction inspectors may choose to accept test results and certification for a 'brand-name' mix from a soil supplier.

Tests must be conducted within 120 days prior to the delivery date of the bioretention soil to the project site.

Batch-specific test results and certification shall be required for projects installing more than 100 cubic yards of bioretention soil.

### SOIL SPECIFICATIONS

Bioretention soils shall meet the following criteria. "Applicant" refers to the entity proposing the soil mixture for approval by a Permittee.

1. General Requirements – Bioretention soil shall:
  - a. Achieve a long-term, in-place infiltration rate of at least 5 inches per hour.
  - b. Support vigorous plant growth.
  - c. Consist of the following mixture of fine sand and compost, measured on a volume basis:
    - 60%-70% Sand
    - 30%-40% Compost
2. Submittal Requirements – The applicant shall submit to the Permittee for approval:
  - a. A minimum one-gallon size sample of mixed bioretention soil.
  - b. Certification from the soil supplier or an accredited laboratory that the Bioretention Soil meets the requirements of this guideline specification.
  - c. Grain size analysis results of the fine sand component performed in accordance with ASTM D 422, Standard Test Method for Particle Size Analysis of Soils or Caltrans Test Method (CTM) C202.
  - d. Quality analysis results for compost performed in accordance with Seal of Testing Assurance (STA) standards, as specified in 4.
  - e. Organic content test results of mixed Bioretention Soil. Organic content test shall be performed in accordance with by Testing Methods for the Examination of Compost and Composting (TMECC) 05.07A, "Loss-On-Ignition Organic Matter Method".
  - f. Grain size analysis results of compost component performed in accordance with ASTM D 422, Standard Test Method for Particle Size Analysis of Soils.
  - g. A description of the equipment and methods used to mix the sand and compost to produce Bioretention Soil.

h. Provide the name of the testing laboratory(s) and the following information:

- (1) Contact person(s)
- (2) Address(s)
- (3) Phone contact(s)
- (4) E-mail address(s)
- (5) Qualifications of laboratory(s), and personnel including date of current certification by USCC, ASTM, Caltrans, or approved equal

3. Sand for Bioretention Soil

- a. Sand shall be free of wood, waste, coating such as clay, stone dust, carbonate, etc., or any other deleterious material. All aggregate passing the No. 200 sieve size shall be nonplastic.
- b. Sand for Bioretention Soils shall be analyzed by an accredited lab using #200, #100, #40 or #50, #30, #16, #8, #4, and 3/8 inch sieves (ASTM D 422, CTM 202 or as approved by municipality), and meet the following gradation:

Sieve Size	Percent Passing (by weight)	
	<i>Min</i>	<i>Max</i>
3/8 inch	100	100
No. 4	90	100
No. 8	70	100
No. 16	40	95
No. 30	15	70
No. 40 or No.50	5	55
No. 100	0	15
No. 200	0	5

Note: all sands complying with ASTM C33 for fine aggregate comply with the above gradation requirements.

4. Composted Material

Compost shall be a well decomposed, stable, weed free organic matter source derived from waste materials including yard debris, wood wastes or other organic materials not including manure or biosolids meeting the standards developed by the US Composting Council (USCC). The product shall be certified through the USCC Seal of Testing Assurance (STA) Program (a compost testing and information disclosure program).

- a. Compost Quality Analysis by Laboratory – Before delivery of the soil, the supplier shall submit a copy of lab analysis performed by a laboratory that is enrolled in the US Composting Council’s Compost Analysis Proficiency (CAP) program and using approved Test Methods for the Examination of Composting and Compost (TMECC). The lab report shall verify:
  - (1) Organic Matter Content: 35% - 75% by dry wt.
  - (2) Carbon and Nitrogen Ratio: C:N < 25:1 and C:N >15:1
  - (3) Maturity/Stability: Any one of the following is required to indicate stability:
    - (i) Oxygen Test < 1.3 O<sub>2</sub> /unit TS /hr
    - (ii) Specific oxy. Test < 1.5 O<sub>2</sub> / unit BVS /hr
    - (iii) Respiration test < 8 mg CO<sub>2</sub>-C /g OM / day
    - (iv) Dewar test < 20 Temp. rise (°C) e.
    - (v) Solvita® > 5 Index value
  - (4) Toxicity: Any one of the following measures is sufficient to indicate non-toxicity.
    - (i) NH<sub>4</sub><sup>+</sup> : NO<sub>3</sub><sup>-</sup>-N < 3
    - (ii) Ammonium < 500 ppm, dry basis
    - (iii) Seed Germination > 80 % of control
    - (iv) Plant Trials > 80% of control
    - (v) Solvita® = 5 Index value
  - (5) Nutrient Content: provide analysis detailing nutrient content including N-P-K, Ca, Na, Mg, S, and B.
    - (i) Total Nitrogen content 0.9% or above preferred.
    - (ii) Boron: Total shall be <80 ppm;
  - (6) Salinity: Must be reported; < 6.0 mmhos/cm
  - (7) pH shall be between 6.2 and 8.2 May vary with plant species.
- b. Compost Quality Analysis by Compost Supplier – Before delivery of the compost to the soil supplier the Compost Supplier shall verify the following:
  - (1) Feedstock materials shall be specified and include one or more of the following: landscaping/yard trimmings, grass clippings, food scraps, and agricultural crop residues.
  - (2) Maturity/Stability: shall have a dark brown color and a soil-like odor. Compost exhibiting a sour or putrid smell or containing recognizable grass or leaves, or is hot (120F) upon delivery or rewetting is not acceptable.
  - (3) Weed seed/pathogen destruction: provide proof of process to further reduce pathogens (PFRP). For example, turned windrows must reach min. 55C for 15 days with at least 5 turnings during that period.
- c. Compost for Bioretention Soil Texture – Compost for bioretention soils shall be analyzed by an accredited lab using #200, 1/4 inch, 1/2 inch, and 1 inch sieves (ASTM D 422 or as approved by municipality), and meet the following gradation:

Sieve Size	Percent Passing (by weight)	
	<i>Min</i>	<i>Max</i>

1 inch	99	100
1/2 inch	90	100
1/4 inch	40	90
No. 200	1	10

- d. Bulk density shall be between 500 and 1100 dry lbs/cubic yard
- e. Moisture content shall be between 30% - 55% of dry solids.
- f. Inerts – compost shall be relatively free of inert ingredients, including glass, plastic and paper, < 1 % by weight or volume.
- g. Select Pathogens – Salmonella <3 MPN/4grams of TS, or Coliform Bacteria <10000 MPN/gram.
- h. Trace Contaminants Metals (Lead, Mercury, Etc.) – Product must meet US EPA, 40 CFR 503 regulations.
- i. Compost Testing – The compost supplier will test all compost products within 120 calendar days prior to application. Samples will be taken using the STA sample collection protocol. (The sample collection protocol can be obtained from the U.S. Composting Council, 4250 Veterans Memorial Highway, Suite 275, Holbrook, NY 11741 Phone: 631-737-4931, [www.compostingcouncil.org](http://www.compostingcouncil.org)). The sample shall be sent to an independent STA Program approved lab. The compost supplier will pay for the test.

**VERIFICATION OF ALTERNATIVE BIORETENTION SOIL MIXES**

Bioretention soils not meeting the above criteria shall be evaluated on a case by case basis. Alternative bioretention soil shall meet the following specification: “Soils for bioretention facilities shall be sufficiently permeable to infiltrate runoff at a minimum rate of 5 inches per hour during the life of the facility, and provide sufficient retention of moisture and nutrients to support healthy vegetation.”

The following steps shall be followed by municipalities to verify that alternative soil mixes meet the specification:

- 1. General Requirements – Bioretention soil shall achieve a long-term, in-place infiltration rate of at least 5 inches per hour. Bioretention soil shall also support vigorous plant growth. The applicant refers to the entity proposing the soil mixture for approval.
  - a. Submittals – The applicant must submit to the municipality for approval:
    - (1) A minimum one-gallon size sample of mixed bioretention soil.
    - (2) Certification from the soil supplier or an accredited laboratory that the Bioretention Soil meets the requirements of this guideline specification.

- (3) Certification from an accredited geotechnical testing laboratory that the Bioretention Soil has an infiltration rate between 5 and 12 inches per hour as tested according to Section 1.b.(2)(ii).
- (4) Organic content test results of mixed Bioretention Soil. Organic content test shall be performed in accordance with by Testing Methods for the Examination of Compost and Composting (TMECC) 05.07A, “Loss-On-Ignition Organic Matter Method”.
- (5) Grain size analysis results of mixed bioretention soil performed in accordance with ASTM D 422, Standard Test Method for Particle Size Analysis of Soils.
- (6) A description of the equipment and methods used to mix the sand and compost to produce Bioretention Soil.
- (7) The name of the testing laboratory(s) and the following information:
  - (i) Contact person(s)
  - (ii) Address(s)
  - (iii) Phone contact(s)
  - (iv) E-mail address(s)
  - (v) Qualifications of laboratory(s), and personnel including date of current certification by STA, ASTM, or approved equal.

**b. Bioretention Soil**

- (1) Bioretention Soil Texture: Bioretention Soils shall be analyzed by an accredited lab using #200, and 1/2” inch sieves (ASTM D 422 or as approved by municipality), and meet the following gradation:

Sieve Size	Percent Passing (by weight)	
	<i>Min</i>	<i>Max</i>
1/2 inch	97	100
No. 200	2	5

- (2) Bioretention Soil Permeability testing: Bioretention Soils shall be analyzed by an accredited geotechnical lab for the following tests:
  - (i) Moisture – density relationships (compaction tests) shall be conducted on bioretention soil. Bioretention soil for the permeability test shall be compacted to 85 to 90 percent of the maximum dry density (ASTM D1557).
  - (ii) Constant head permeability testing in accordance with ASTM D2434 shall be conducted on a minimum of two samples with a 6-inch mold and vacuum saturation.

**MULCH FOR BIORETENTION FACILITIES**

Three inches of mulch is recommended for the purpose of retaining moisture, preventing erosion and minimizing weed growth. Projects subject to the State’s Model Water Efficiency Landscaping Ordinance (or comparable local ordinance) will be required to provide at least three inches of mulch. Aged mulch, also called compost mulch, reduces the ability of weeds to establish, keeps soil moist, and replenishes soil nutrients. Aged mulch can be obtained through soil suppliers or directly from commercial recycling yards. It is recommended to apply 1" to 2" of composted mulch, once a year, preferably in June following weeding.

---

**San Francisco Bay Regional Water Quality Control Board**

April 18, 2016  
CIWQS Place No. 756972 (SKM)

To: Municipal Regional Stormwater NPDES Permit (Order No. R2-2015-0049)  
Permittees

*Sent via email to:*

Mr. James Scanlin, Alameda Countywide Clean Water Program:

[jimd@acpwa.org](mailto:jimd@acpwa.org)

Mr. Tom Dalziel, Contra Costa Clean Water Program: [tdalz@pw.cccounty.us](mailto:tdalz@pw.cccounty.us)

Mr. Kevin Cullen, Fairfield-Suisun Urban Runoff Management Program:

[kcullen@fssd.com](mailto:kcullen@fssd.com)

Matt Fabry, San Mateo countywide Water Pollution Prevention Program:

[mfabry@smcgov.org](mailto:mfabry@smcgov.org)

Adam Olivieri, Santa Clara Valley Urban Runoff Pollution Prevention Program:

[awo@eoainc.com](mailto:awo@eoainc.com)

Doug Scott, Vallejo Sanitation and Flood Control District: [dscott@vsfcd.com](mailto:dscott@vsfcd.com)

Geoff Brosseau, Bay Area Stormwater Management Agencies Association:

[Geoff@brosseau.us](mailto:Geoff@brosseau.us)

**Subject: Approval of Revisions to Biotreatment Soil Media Specifications in Water Board Order No. R2-2015-0049, Municipal Regional Stormwater NPDES Permit**

On February 5, 2016, the Bay Area Stormwater Management Agencies Association (BASMAA) submitted proposed revisions to the biotreatment soil media specifications referenced in Provision C.3.c.i.(2)(c)(ii) of Board Order No. R2-2015-0049, the Municipal Regional Stormwater NPDES Permit (MRP). The proposed revisions were submitted on behalf of the 76 Permittees regulated by the MRP and were submitted as allowed under and in accordance with the requirements of Provision C.3.c.i.(2)(c)(ii).

The proposed revisions address issues with the current soil media specifications that Permittees have identified, based on implementation of these soil media specifications for the last 5 years under the previous MRP. These identified issues are as follows:

- Compost suppliers are having difficulties meeting the gradation specifications, soluble boron criteria, and occasionally the pH limits listed in the specifications.
- The specifications contain typographical errors and missing or incorrectly identified units of measurement.

This letter approves the Permittees' proposed changes to the biotreatment soil media specifications referenced in Provision C.3.c.i.(2)(c)(ii) of the MRP. We understand that BASMAA intends to convene a soil specification roundtable in Spring 2016 to investigate the need for alternative specifications that might enhance the performance of bioretention facilities under varying microclimates and drought conditions and with diverse planting palettes, including trees.

If you have questions, please contact Sue Ma of my staff at (510) 622-2386 or via email to [sma@waterboards.ca.gov](mailto:sma@waterboards.ca.gov).

Sincerely,

for Bruce H. Wolfe  
Executive Officer



# Biotreatment Soil Mix

## Specification Verification Checklist

---

This checklist is intended to supply municipal staff, contractors, designers and others with an easy-to-read summary of the detailed information needed to verify that the biotreatment soil mix being provided by the Soil Mix Supplier meets the BASMAA Regional Biotreatment Soil Specification<sup>1</sup> approved by the Regional Water Board Executive Officer on April 18, 2016<sup>2</sup>.

The checklist should be provided to the Soil Mix Supplier by the municipality or contractor before the soil mix has been ordered to allow for sufficient time to compile the information and time to review the completed checklist before delivery of the soil mix to the job site.

Use of this checklist is not required by the MRP and is intended only for assistance in reviewing submittals. Additionally or alternatively, the one page Supplier Certification Statement, developed by the stormwater programs listed below, can be requested from the Supplier to guarantee that the product meets the specification.

The Certification Statement, a list of Soil Mix Suppliers, the BASMAA Regional Biotreatment Soil Specification (2016) and other materials are available at the following websites:

- Santa Clara Valley Urban Runoff Pollution Prevention Program:  
[www.scvurppp-w2k.com/nd\\_wp.shtml](http://www.scvurppp-w2k.com/nd_wp.shtml)
- San Mateo Countywide Water Pollution Prevention Program:  
[www.flowstobay.org/newdevelopment](http://www.flowstobay.org/newdevelopment)
- Alameda Countywide Clean Water Program:  
[www.cleanwaterprogram.org](http://www.cleanwaterprogram.org) (click on "Resources," then "Development")

If a municipality chooses to use the checklist, the following five items are required to be submitted by the Soil Mix Supplier to the requesting municipality or contractor:

- **Sample of the Biotreatment Soil Mix**  
A minimum 1-gallon bag of soil mix.
- **Attachment A – Supplier Analysis of the Biotreatment Soil Mix**  
*To be completed by the Soil Mix Supplier providing the soil mix.*
- **Attachment B – Lab Analysis of Sand Component of the Biotreatment Soil Mix**  
*To be completed by the laboratory conducting the analysis of the sand.*
- **Attachment C – Lab Analysis of Compost Component of the Biotreatment Soil Mix**  
*To be completed by the laboratory conducting the analysis of the compost. Compost analysis of a sample collected (in accordance with the STA sample collection protocol) shall be completed within the last 120 days. Analysis must be completed by a laboratory enrolled in the US Composting Council's Compost Analysis Proficiency program, and shall use the Test Methods for the Evaluation of Composting and Compost (TMECC).*
- **Attachment D – Supplier Analysis of Compost Component of the Biotreatment Soil Mix**  
*To be completed by the Compost Supplier providing the compost component of the soil mix.*

1. [www.basmaa.org](http://www.basmaa.org)

2. [www.swrcb.ca.gov/rwqcb2/water\\_issues/programs/stormwater/mrp.shtml](http://www.swrcb.ca.gov/rwqcb2/water_issues/programs/stormwater/mrp.shtml)

# Attachment A

## Supplier Analysis of Biotreatment Soil Mix

The table below shall be completed by the Biotreatment Soil Mix Supplier.

<b>Date:</b>		<b>Name of Person Filling Out This Form:</b>		
<b>(All lab tests must be done within the last 120 days)</b>				
<b>Title:</b>		<b>Signature:</b>		
<b>Phone:</b>		<b>Email:</b>		
<b>Company Name:</b>		<b>City:</b>		
<b>Street Address:</b>		<b>Zip:</b>		
I certify that the provided Biotreatment Soil Mix meets the requirements of the BASMAA Regional Biotreatment Soil Specification (2016).		<input type="checkbox"/> Yes (Pass)		
		<input type="checkbox"/> No (Fail)		
Describe the equipment and methods used to mix the compost and sand components of the Biotreatment Soil Mix.				
<b>Material</b>	<b>Standard Percent (by volume)</b>	<b>Actual Mix %</b>	<b>Pass</b>	<b>Fail</b>
Sand	60% - 70%		<input type="checkbox"/>	<input type="checkbox"/>
Compost	30% - 40%		<input type="checkbox"/>	<input type="checkbox"/>
Does the soil mix have a permeability of at least 5 inches per hour? <sup>1</sup>			<input type="checkbox"/> Yes (Pass)	
			<input type="checkbox"/> No (Fail)	
Will the soil mix support vigorous plant growth?			<input type="checkbox"/> Yes (Pass)	
			<input type="checkbox"/> No (Fail)	

<sup>1</sup>Soil mix permeability testing is only required for alternative biotreatment soil mixes. Soil permeability tests must be conducted on a minimum of two samples using constant head permeability in accordance with ASTM D2434 with a 6-inch mold and vacuum saturation.

# Attachment B

## Lab Analysis of Sand Component of Biotreatment Soil Mix

The table below shall be completed by the laboratory conducting the sand analysis.

<b>Name of Person Filling Out This Form:</b>		<b>Signature:</b>		
<b>Title:</b>		<b>Date:</b>		
<b>Phone:</b>		<b>Email:</b>		
<b>Company:</b>		<b>City:</b>		
<b>Street Address:</b>		<b>Zip:</b>		
<b>Qualifications &amp; relevant certifications (ASTM, CTM or approved equivalent certifications):</b>				
Is sand free of wood, waste, coating (such as clay, stone dust, carbonate, etc.), or any other deleterious material?		<input type="checkbox"/> Yes (Pass)		
		<input type="checkbox"/> No (Fail)		
Is all aggregate passing the No. 200 sieve non-plastic?		<input type="checkbox"/> Yes (Pass)		
		<input type="checkbox"/> No (Fail)		
Particle size analysis shall be conducted in accordance with ASTM D 422 (Standard Test Method for Particle Size Analysis of Soils) or CTM 202. Other equivalent methods acceptable only if approved.				
Sieve Size	Standard Percent Passing (% by weight)	Testing Results (%)	Pass	Fail
3/8 inch	100%		<input type="checkbox"/>	<input type="checkbox"/>
No. 4	90% - 100%		<input type="checkbox"/>	<input type="checkbox"/>
No. 8	70% - 100%		<input type="checkbox"/>	<input type="checkbox"/>
No. 16	40% - 95%		<input type="checkbox"/>	<input type="checkbox"/>
No. 30	15% - 70%		<input type="checkbox"/>	<input type="checkbox"/>
No. 40 or 50	5% - 55%		<input type="checkbox"/>	<input type="checkbox"/>
No. 100	0% - 15%		<input type="checkbox"/>	<input type="checkbox"/>
No. 200	0% - 5%		<input type="checkbox"/>	<input type="checkbox"/>

# Attachment C

## Lab Analysis of Compost Component of Biotreatment Soil Mix

The table below shall be completed by the laboratory conducting the compost analysis.

<b>Name of Person Filling Out This Form:</b>	<b>Signature:</b>
<b>Title:</b>	<b>Date:</b>
<b>Phone:</b>	<b>Email:</b>
<b>Company:</b>	<b>City:</b>
<b>Street Address:</b>	<b>Zip:</b>
<b>Qualifications &amp; relevant certifications: (STA, ASTM or approved equivalent certification)</b>	

Specification	Standard	Testing Results	Pass	Fail
<b>Organic Matter Content</b>	35% - 75% (by dry weight)	%	<input type="checkbox"/>	<input type="checkbox"/>
<b>Carbon-to-Nitrogen Ratio</b>	15:1 to 25:1 (C:N)	C:N	<input type="checkbox"/>	<input type="checkbox"/>
<b>Salinity</b>	< 6.0 mm hos/cm	mm hos/cm	<input type="checkbox"/>	<input type="checkbox"/>
<b>pH</b>	6.2 - 8.2	pH	<input type="checkbox"/>	<input type="checkbox"/>
<b>Bulk Density</b>	500 – 1100 dry lbs / yd <sup>3</sup>	dry lbs / yd <sup>3</sup>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Moisture Content</b>	30%-55% (of dry solids)	%	<input type="checkbox"/>	<input type="checkbox"/>
<b>Percent inert ingredients (incl. plastic, glass, paper)</b>	< 1% (by weight or volume)	%	<input type="checkbox"/>	<input type="checkbox"/>

Provide the results of at least one of the following analyses to indicate compost stability:

Specification	Standard	Testing Results	Pass	Fail
<b>Oxygen Test</b>	< 1.3 O <sub>2</sub> /unit TS/hr	O <sub>2</sub> /unit TS/hr	<input type="checkbox"/>	<input type="checkbox"/>
<b>Specific Oxygen Test</b>	< 1.5 O <sub>2</sub> /unit BVS/hr	O <sub>2</sub> /unit BVS/hr	<input type="checkbox"/>	<input type="checkbox"/>
<b>Respiration Test</b>	< 8mg CO <sub>2</sub> -C/g OM/day	mgCO <sub>2</sub> -C/g OM/day	<input type="checkbox"/>	<input type="checkbox"/>
<b>Dewar test</b>	< 20 °C Temp. rise e.	°C Temp. rise e.	<input type="checkbox"/>	<input type="checkbox"/>
<b>Solvita® Index value</b>	> 5 Index value	Index value	<input type="checkbox"/>	<input type="checkbox"/>

Provide the results of <u>at least one</u> of the following analyses to indicate compost toxicity:					
Specification	Standard	Testing Results		Pass	Fail
Ratio NH <sub>4</sub> <sup>+</sup> -N: NO <sub>3</sub> <sup>-</sup> -N	< 3		NH <sub>4</sub> <sup>+</sup> -N : NO <sub>3</sub> <sup>-</sup> -N	<input type="checkbox"/>	<input type="checkbox"/>
Ammonium	< 500 ppm, dry basis		ppm, dry basis	<input type="checkbox"/>	<input type="checkbox"/>
Seed Germination	> 80% of control		% of control	<input type="checkbox"/>	<input type="checkbox"/>
Plant Trials	> 80% of control		% of control	<input type="checkbox"/>	<input type="checkbox"/>
Solvita® Index value	= 5 Index value		Index value	<input type="checkbox"/>	<input type="checkbox"/>
Provide the analysis of the nutrient content of the compost, including the following:					
Specification	Standard	Testing Results		Pass	Fail
Boron (total, in ppm)	< 80 ppm		ppm	<input type="checkbox"/>	<input type="checkbox"/>
Nitrogen (N)(total %)	> 0.9% preferred.		%	<input type="checkbox"/>	<input type="checkbox"/>
Phosphorus (as P <sub>2</sub> O <sub>5</sub> )	<i>[not specified]</i>		%		
Potassium (as K <sub>2</sub> O)	<i>[not specified]</i>		%		
Calcium (Ca)	<i>[not specified]</i>		%		
Sodium (Na)	<i>[not specified]</i>		%		
Magnesium (Mg)	<i>[not specified]</i>		%		
Sulfur (S)	<i>[not specified]</i>		ppm		
Provide the results of <u>at least one</u> of the following select pathogens:					
Specification	Standard	Testing Results		Pass	Fail
Salmonella	< 3 MPN/4 grams TS		MPN/4 grams TS	<input type="checkbox"/>	<input type="checkbox"/>
Coliform Bacteria	< 10,000 MPN/gram		MPN/gram	<input type="checkbox"/>	<input type="checkbox"/>
Does the product meet US EPA, 40CFR 503 regulations regarding trace contaminants metals (Lead, Mercury, etc.)?				<input type="checkbox"/> Yes (Pass)	
				<input type="checkbox"/> No (Fail)	
Particle size analysis shall be conducted in accordance with ASTM D 422 (Standard Test Method for Particle Size Analysis of Soils)-washing not required. Equivalent methods acceptable if approved.					
Sieve Size	Standard Percent Passing (by weight)	Testing Results (%)		Pass	Fail
1 inch	99% - 100%			<input type="checkbox"/>	<input type="checkbox"/>
½ inch	90% - 100%			<input type="checkbox"/>	<input type="checkbox"/>
¼ inch	40% - 90%			<input type="checkbox"/>	<input type="checkbox"/>
No. 200	1% - 10%			<input type="checkbox"/>	<input type="checkbox"/>

# Attachment D

## Supplier Analysis of Compost Component of Biotreatment Soil Mix

*The table below shall be completed by the Compost Supplier providing the compost for the mix.*

<b>Name of Company:</b>	<b>Date of Delivery:</b>
<b>Qualifications &amp; relevant certifications:</b> (STA, ASTM or approved equivalent certifications)	<b>Date of the Compost Lab Analysis Report:</b> (Must be dated within 120 days prior to delivery)
<b>Name of Person Filling Out This Form:</b>	<b>Date:</b>
<b>Signature:</b>	<b>Street Address:</b>
<b>Email address:</b>	<b>City:</b>
<b>Phone:</b>	<b>Zip:</b>
Feedstock materials have been specified and include only the following: Landscape/yard trimmings, grass clippings, food scraps, or agricultural crop residues?	<input type="checkbox"/> Yes (Pass)
	<input type="checkbox"/> No (Fail)
Compost has a dark brown color and a soil-like odor, does not exhibit a sour or putrid smell, does not contain recognizable grass or leaves, and is not hot (120°F) upon delivery or rewetting?	<input type="checkbox"/> Yes (Pass)
	<input type="checkbox"/> No (Fail)
The compost has gone through the process to further reduce pathogens (PFRP)? For example, turned windrows must reach a minimum temperature of 55°C for 15 days with at least 5 turnings during that period.	<input type="checkbox"/> Yes (Pass)
	<input type="checkbox"/> No (Fail)



## BIOTREATMENT SOIL MIX SUPPLIER LIST

Company	Contact Name	Phone	Address	City	Zip	E-mail	Website
American Soil & Stone Products Inc.	Ryan Hoffman	510-292-3018	Richmond Annex, 2121 San Joaquin Street, Building A	Richmond	94804	<a href="mailto:ryan@americansoil.com">ryan@americansoil.com</a>	<a href="http://www.americansoil.com">www.americansoil.com</a>
L.H. Voss Materials, Inc.	Nyoka Corley	925-676-7910	5965 Dougherty Road	Dublin	94568	<a href="mailto:nyoka.corley@gmail.com">nyoka.corley@gmail.com</a>	<a href="http://www.lhvoss.com">www.lhvoss.com</a>
Lehigh Hanson Aggregates	Chris Stromberg	510-246-0393	4501 Tidewater Avenue	Oakland	94601	<a href="mailto:chris.stromberg@lehighhanson.com">chris.stromberg@lehighhanson.com</a>	<a href="http://www.lehighhanson.com">www.lehighhanson.com</a>
Lyngso Garden Materials, Inc.	Paul Truyts	650-333-1044 650-364-1730	19 Seaport Boulevard	Redwood City	94063	<a href="mailto:ptruyts@lyngsogarden.com">ptruyts@lyngsogarden.com</a>	<a href="http://www.lyngsogarden.com">www.lyngsogarden.com</a>
Marshall Brothers Enterprises, Inc.	Phillip Marshall	925-449-4020	P.O. Box 2188	Livermore	94551	<a href="mailto:phillip@mbenterprises.com">phillip@mbenterprises.com</a>	<a href="http://www.mbenterprises.com">www.mbenterprises.com</a>
Pleasanton Trucking Inc.	Tom Bonnell	925-449-5400	P.O. Box 11462	Pleasanton	94588	<a href="mailto:pleasanton_trucking@yahoo.com">pleasanton_trucking@yahoo.com</a>	<a href="http://www.pleasantontrucking.com">www.pleasantontrucking.com</a>
Recology Blossom Valley Organics	Denette Covarrubias	209-545-7718 209-597-1209	6133 Hammett Court	Modesto	95358	<a href="mailto:dcovarrubias@recology.com">dcovarrubias@recology.com</a>	<a href="http://www.recology.com/blossom-valley-organics-modesto/">www.recology.com/blossom-valley-organics-modesto/</a>
Redi-Gro Corporation	Sharon Yon	916-381-6063 800-654-4358	8909 Elder Creek Road	Sacramento	95828	<a href="mailto:redigropro@redi-gro.com">redigropro@redi-gro.com</a>	<a href="http://www.redi-gro.com">www.redi-gro.com</a>
TMT Enterprises, Inc.	Matt Moore	408-432-9040	1996 Oakland Road	San Jose	95131	<a href="mailto:info@tmtenterprises.net">info@tmtenterprises.net</a>	<a href="http://www.tmtenterprises.net">www.tmtenterprises.net</a>

As of: 10/31/2017

Disclaimer: ACCWP provides this list of biotreatment soil mix suppliers for the use of its member agencies, contractors, designers and others in finding suppliers for their projects. Suppliers are listed based on a general review of their soil mix product including test results, adherence to the biotreatment soil specification approved by the Regional Water Board Executive Officer on April 18, 2016, and knowledge of the specification. Therefore users of this ACCWP list must make the final determination as to the products and adherence to the approved biotreatment soil specification. Users of the list assume all liability directly or indirectly arising from use of this list. The listing of any soil supplier is not to be construed as an actual or implied endorsement, recommendation, or warranty of such soil provider or their products, nor is criticism implied of similar soil suppliers that are not listed. This disclaimer is applicable whether the information is obtained in hard copy or downloaded from the Internet. Check the ACCWP website for the "Biotreatment Soil Mix Verification Checklist" and "Biotreatment Soil Mix Supplier Verification Statement" for assistance in reviewing and approving soil mix submittals, <http://cleanwaterprogram.org> (click on "Resources," then "Development.")

<COMPANY NAME>  
<ADDRESS>

To: <city rep, contractor or other appropriate party>

Job Ref: <XYZ STREET, PROJECT# 1234>

Certificate of Compliance for Biotreatment Soil Mix

I hereby certify that the Biotreatment Soil Mix, to be delivered to the project cited above from our company, meets the "Soil Specifications" criteria approved by the Executive Officer of the San Francisco Bay Regional Water Quality Control Board on April 18, 2016, in accordance with Provision C.3.c.i.(2)(c)(ii) of the Municipal Regional Stormwater NPDES Permit (MRP) adopted on November 19, 2015.

A copy of this Certificate of Compliance will be provided with the delivery of the soil mix. Our test results have been conducted within 120 days prior to the delivery date of the biotreatment soil mix to the project site.

Thank You,

Signed: \_\_\_\_\_

Name: \_\_\_\_\_

Title: \_\_\_\_\_

Contact email address \_\_\_\_\_

Contact phone number \_\_\_\_\_