



MEMBER AGENCIES:

Alameda  
Albany  
Berkeley  
Dublin  
Emeryville  
Fremont  
Hayward  
Livermore  
Newark  
Oakland  
Piedmont  
Pleasanton  
San Leandro  
Union City  
County of Alameda  
Alameda County Flood  
Control and Water  
Conservation District  
Zone 7 Water Agency

# C.3 Stormwater Technical Guidance

2<sup>nd</sup> Revised Draft  
September 11, 2019

A handbook for  
developers,  
builders and  
project  
applicants

Version 7

# Local Contacts

Please contact the local agency with any questions regarding requirements specific to the local jurisdiction, using contact information provided below.

Alameda (City): Public Works Department, 510.747.7930

Alameda County Flood Control and Water Conservation District: 510.670.5543  
339 Elmhurst Street, 1st Floor, Permit Center, Hayward, CA 94544

Albany: Community Development and Environmental Resources Department  
1000 San Pablo Avenue, Albany, CA 94706. 510.528.5760  
[www.albanyca.org](http://www.albanyca.org)

Berkeley: 510.981.6421, 510.981.6409

Dublin: Environmental Programs Division, Public Works Department:  
925-833-6630

Emeryville: Environmental Programs, Public Works, 510.596.3728

Fremont: Environmental Services Division, 39550 Liberty Street, Fremont, CA  
94538, 510.494.4570, [www.fremont.gov/stormwaterdevelopment](http://www.fremont.gov/stormwaterdevelopment)

Hayward: Engineering and Transportation Division, 510.583.4785

Livermore: 925.960.8100 (Inspection/reporting), 925.960.4500 (C.3 Technical Info)  
Permit Center, 1052 South Livermore, Ave. Livermore, CA 94550

Newark: Michael Carmen or Soren Fajeau, City Hall – Public Works  
37101 Newark Boulevard, 1st Floor, Newark CA 94560, 510.578.4320

Oakland: Permit Center, 250 Frank H. Ogawa Plaza, 2<sup>nd</sup> Floor, Oakland, CA 94612  
510.238.3911, [www.oaklandnet.com](http://www.oaklandnet.com)

Piedmont: Public Works Counter, City Hall, 120 Vista Avenue, Piedmont, CA 94611;  
510.420.3050; [www.ci.piedmont.ca.us](http://www.ci.piedmont.ca.us)

Pleasanton: Engineering Land Development, 200 Old Bernal Road,  
Pleasanton, CA 94566, 925.931.5650, [www.cityofpleasantonca.gov](http://www.cityofpleasantonca.gov)

San Leandro: Engineering and Transportation Department, Civic Center  
835 East 14<sup>th</sup> Street, San Leandro, CA 94577  
Michael Stella, 510.577.3433, [MStella@sanleandro.org](mailto:MStella@sanleandro.org) OR  
Vibha Deshmukh, 510.577.3411, [VDeshmukh@sanleandro.org](mailto:VDeshmukh@sanleandro.org)

Union City: Farooq Azim, [fazim@unioncity.org](mailto:fazim@unioncity.org), 510.675.5368  
34009 Alvarado-Niles Road, Union City, CA 94587

Unincorporated Alameda County: 510.670.5543  
339 Elmhurst Street, 1st Floor, Permit Center, Hayward, CA 94544  
John Rogers, 510.670.5402, [johnr@acwpa.org](mailto:johnr@acwpa.org)

Zone 7 Water Agency: 925.454.5036

# Credits

The Clean Water Program extends its appreciation to all those who contributed to this document, which was developed under the guidance of the C.3 Technical Guidance Work Group and New Development Subcommittee. We appreciate the comments, suggestions, and guidance provided by the participating subcommittee members listed below.

## **New Development Subcommittee 2019**

Daniel Matlock, City of Fremont, Chair  
Jim Barse, City of Alameda  
Vincent Chen, City of Berkeley  
Mitch Buttress, City of Berkeley  
Laurie Sucgang, City of Dublin  
Nancy Humphrey, City of Emeryville  
Maria Javier, City of Fremont  
Domingo Trinidad, City of Hayward  
Steve Aguiar, City of Livermore  
Debbie Salgado, City of Livermore

Jayson Imai, City of Newark  
Christine Chou, City of Newark  
Dennis Larks, City of Oakland  
Michael Stella, City of San Leandro  
Vibha Deshmukh, City of San Leandro  
Farooq Azim, City of Union City  
Sharon Gosselin, Alameda County PW  
James Scanlin, Clean Water Program  
Laura Prickett, Horizon

The Clean Water Program recognizes the firms that helped prepare this document under the direction of the Subcommittee. EOA, Inc. prepared most of the original chapters and sections of the document; Horizon Water and Environment (Horizon) has made all revisions included in Version 7. BKF Engineers prepared the original technical guidance for some of the specific stormwater controls. Placeworks prepared Appendix B (Planting Guidance,) with assistance from Stopwaste and Four Dimensions Landscape Company. The Version 7 update of the plant list included in Appendix B was prepared by Paul Niemuth, ASLA, Landscape Architect for the City of Fremont.

The Clean Water Program gratefully acknowledges the public agencies whose post-construction stormwater guidance documents served as inspiration and models for this document including: the Contra Costa Countywide Clean Water Program's C.3 Stormwater Guidebook; the Milpitas C.3 Stormwater Guidebook, the Santa Clara Valley Urban Runoff Pollution Prevention Program's C.3 Stormwater Handbook; the Santa Rosa Area SUSMP Guidelines; Portland, Oregon's Stormwater Management Manual; and the San Mateo Countywide Water Pollution Prevention Program's C.3 Technical Guidance and Sustainable Green Streets and Parking Lots Design Guidebook.

# Table of Contents

Page

<b>Glossary of Terms .....</b>	<b>vii</b>
<b>Chapter 1 – Introduction / How to Use this Handbook.....</b>	<b>1-1</b>
1.1 Purpose of this Handbook.....	1-1
1.2 What is the Clean Water Program? .....	1-2
1.3 How to Use this Handbook.....	1-2
1.4 Precedence.....	1-4
<b>Chapter 2 – Background / Regulatory Requirements .....</b>	<b>2-1</b>
2.1 Stormwater Problems in Developed Areas.....	2-1
2.2 Post-Construction Stormwater Controls.....	2-3
2.3 Municipal Stormwater Permit Requirements.....	2-5
<b>Chapter 3 – Preparing Permit Application Submittals .....</b>	<b>3-1</b>
3.1 The Development Review Process .....	3-1
3.2 How to Prepare Planning Permit Submittals.....	3-3
3.3 Building Permit Submittals.....	3-15
3.4 Simple Instructions for Small Sites Subject to Stormwater Treatment Requirements.....	3-17
<b>Chapter 4 – Site Design Measures .....</b>	<b>1</b>
4.1 Self-Treating Areas .....	4-2
4.2 Self-Retaining Areas .....	4-4
4.3 Reducing the Size of Impervious Areas .....	4-6
4.4 Rainwater Harvesting and Use .....	4-8
4.5 Tree Preservation/Planting and Interceptor Tree Credits .....	4-8
4.6 Site Design Requirements for Small Projects.....	4-12
<b>Chapter 5 – General Technical Guidance for Treatment Measures .....</b>	<b>5-1</b>
5.1 Hydraulic Sizing Criteria .....	5-1
5.2 Applicability of Non-Low Impact Development (LID) Treatment.....	5-12
5.3 Using Treatment Trains.....	5-12
5.4 Infiltration Guidelines.....	5-13

5.5 Underdrains in Biotreatment Measures .....5-14

5.6 Technical Guidance for Low-Flow Systems .....5-14

5.7 Plant Selection and Maintenance .....5-16

5.8 Mosquito Control .....5-18

5.9 Incorporating Hydromodification Management.....5-18

5.10 Getting Water into Treatment Measures .....5-19

**Chapter 6 – Technical Guidance for Specific Treatment Measures ..... 6-1**

6.1 Bioretention Area.....6-2

6.2 Flow-Through Planter .....6-10

6.3 Tree Well Filter.....6-16

6.4 Infiltration Trench .....6-21

6.5 Extended Detention Basin .....6-25

6.6 Pervious Paving.....6-29

6.7 Grid Pavements.....6-35

6.8 Green Roofs .....6-39

6.9 Rainwater Harvesting and Use.....6-42

6.10 Media Filter.....6-46

6.11 Subsurface Infiltration System.....6-50

**Chapter 7 – Hydromodification Management Measures ..... 7-1**

7.1 Why Require Hydromodification Management?.....7-1

7.2 Which Projects Need to Implement HM? .....7-3

7.3 Hydromodification Management (HM) Measures .....7-4

7.4 Requirements for Hydromodification Management .....7-6

7.5 HM Control Submittals for Review .....7-9

7.6 Area-Specific HM Provisions .....7-10

**Chapter 8 – Operation and Maintenance ..... 8-1**

8.1 Summary of O&M Requirements .....8-1

8.2 Preparing Maintenance-Related Documents .....8-4

**Chapter 9 – Alternative Compliance ..... 9-1**

9.1 What is Alternative Compliance?.....9-1

9.2 Categories of Alternative Compliance .....9-1

9.3 Offsite or Regional Project Completion Deadlinescompletion deadlines.....9-1

9.4 When Does the Alternative Compliance Provision Take Effect? .....9-1

**References ..... R-1**

**Appendix A – Local Requirements**

**Appendix B – Plant List and Planting Guidance**

**Appendix C – Example Scenarios and Spreadsheet Tools for Sizing Stormwater Treatment Measures**

**Appendix D – Mean Annual Precipitation Map**

**Appendix E – Applicability of Non-Low Impact Development Treatment Measures**

**Appendix F – Infiltration Guidelines**

**Appendix G – Mosquito Control Guidelines**

**Appendix H – Operation & Maintenance Document Templates**

**Appendix I – HM Susceptibility Map**

**Appendix J – Special Projects**

**Appendix K – Soil Specifications**

**Appendix L – Site Design Requirements for Small Projects**

**Appendix M – Green Streets**

**Appendix N – Rainwater Harvesting and Use**

# List of Tables

	Page
Table 2-1. Projects Excluded from Provision C.3 Numerically Sized Treatment Requirements.....	2-7
Table 3-1. Planning Permit Submittal Checklist.....	3-4
Table 3-2. Example Table of Stormwater Source Controls.....	3-13
Table 3-3. Building Permit Submittal Checklist.....	3-15
Table 4-1. Stormwater Treatment Credits for Interceptor Trees.....	4-9
Table 5-1. Flow and Volume Based Treatment Measure Designs.....	5-3
Table 5-2. Unit Basin Storage Volume (Inches) for 80 Percent Capture with 48-Hour Drawdown Time.....	5-5
Table 5-3. Flow-based Sizing Criteria Included in MRP Provision C.3.d.....	5-6
Table 5-4. Estimated Runoff Coefficients for Various Surfaces During Small Storms.....	5-8
Table 7-1. HM Control Plan Checklist.....	7-10

# List of Figures

	Page
Figure 2-1. The Water Cycle.....	2-1
Figure 2-2. Change in Volume of Stormwater Runoff after Development.....	2-2
Figure 3-1. Sample Development Review Process for C.3 Regulated Projects.....	3-2
Figure 4-1. Commercial/Industrial Site Compared to Same Site with Self-Treating Areas.....	4-3
Figure 4-2. Self-Treating Area Usage.....	4-3
Figure 4-3. Schematic Drainage Plan for Site with a Self-Treating Area.....	4-4
Figure 4-4. Comparison of Conventional Design and Self-Retaining Area.....	4-5
Figure 4-5. Schematic Drainage Plan for Site with a Self-Retaining Area.....	4-6
Figure 4-6. Schematic Illustration of an Installed Load-bearing Modular Grid Product.....	4-12
Figure 5-1. Stepped Manhole Design.....	5-15
Figure 5-2. StormGate™ Flow Splitter Structure.....	5-15
Figure 5-3. Standard Curb Cut: section view.....	5-21

**C.3 STORMWATER TECHNICAL GUIDANCE**

Figure 5-4. Standard Curb Cut: plan view .....5-21

Figure 5-5. Standard Curb Cut with Side Wings: cut section view .....5-22

Figure 5-6. Standard Curb Cut with Side Wings: plan view .....5-22

Figure 5-7. Opening between Wheelstop Curbs: section view .....5-23

Figure 5-8. Opening between Wheelstop Curbs: plan view .....5-23

Figure 5-9. Grated Curb Cut: section view .....5-24

Figure 5-10. Grated Curb Cut: plan view.....5-24

Figure 6.1-1 Planter on Slope Provides more Storage.....6-3

Figure 6.1-2 Bioretention Cells with Check Dams.....6-3

Figure 6.1-3 Key Check Dams into Bottom and Side Slopes.....6-3

Figure 6.1-4. Cross Section, Bioretention Area: side view .....6-7

Figure 6.1-5. Check Dam for Installing a Series of Linear Bioretention Cells in Sloped Area: plan view and profile .....6-8

Figure 6.1-6. Cross-section of Bioretention Area Showing Inlet from Pavement .....6-8

Figure 6.1-7. Cross-section of Lined Bioretention Area .....6-9

Figure 6.1-8. Tree Planting on Soil Pedestal.....6-9

Figure 6.2-1. Plan View of Planter with One Inlet.....6-13

Figure 6.2-2. Cross-section A-A of Flow Through Planter.....6-14

Figure 6.2-3. Cross-section B-B of Flow Through Planter.....6-15

Figure 6.3-1. Schematic of a Non-proprietary Tree Well Filter.....6-20

Figure 6.4-1. Infiltration Trench Section. ....6-24

Figure 6.5-1. Side View of Riser, Extended Detention Basin .....6-27

Figure 6.5-2. Top View of Riser, Extended Detention Basin (square design).....6-28

Figure 6.5-3. Plan View, Typical Extended Detention Basin .....6-28

Figure 6.6-1. Parking Lot with Pervious Concrete Pavement, Emeryville .....6-29

Figure 6.6-2. Typical Pervious Concrete Pavement.....6-33

Figure 6.6-3. Typical Porous Asphalt Pavement .....6-33

Figure 6.6-4. Typical Permeable Interlocking Concrete Pavement.....6-34

Figure 6.6-5. Underdrain Installation in Pervious Pavement .....6-34

Figure 6.7-1. Plastic Grid Pavement for Occasional Vehicular Use or for Emergency Access Lanes .....6-35

Figure 6.7-2. Concrete Grid Pavement for Occasional Vehicular Use or for Emergency Access Lanes.....6-36



**ALAMEDA COUNTYWIDE CLEAN WATER PROGRAM**

Figure 6.8-1. Green Roof Cross-section .....6-40

Figure 6.10-1. System C Filter Cartridge, Typically Used as Part of Array .....6-46

Figure 6.10-2. Plan View Schematic Detail, Typical System C Filter Array. ....6-48

Figure 6.10-3. Cut Away Profile Views, System A Filter (Modified Delaware Sand Filter) .....6-49

Figure 6.10-4. Cut Away View, Typical System C Filter Array. ....6-49

Figure 7-1. Stormwater Peak Discharges in Urban (Red) and Less Developed (Yellow) Watersheds .....7-1

Figure 7-2. Effects of Urbanization on the Local Hydrologic Cycle .....7-2

Figure 7-3. Variation in rainfall contribution to different components of the hydrological cycle for areas with different intensity of urban development. ....7-2

Figure 7-4. Schematic flow duration pond and flow duration curves matched by varying discharge rates according to detained volume. ....7-8

# Glossary of Terms

<p><b>Alameda Countywide Clean Water Program</b></p>	<p>The Alameda Countywide Clean Water Program (Program) is established by a memorandum of understanding among the 14 Alameda County cities, Alameda County, the Alameda County Flood Control and Water Conservation District, and the Zone 7 Water Agency. All these agencies are listed as Co-permittees in the Municipal Regional Stormwater NPDES Permit (MRP) adopted by the Regional Water Quality Control Board. The Program implements common tasks and assists the member agencies to implement their local stormwater pollution prevention programs.</p>
<p><b>Bay Area Hydrology Model (BAHM)</b></p>	<p>A computer software application to assist project applicants in sizing specialized detention facilities that will allow a project to meet the Flow Duration Control standard where required by the hydromodification management provision (Provision C.3.g) of the Municipal Regional Stormwater NPDES Permit (MRP). The current version of the BAHM (BAHM 2013) is available for download at <a href="http://www.clearcreeksolutions.info/ftp/public/downloads/BAHM2013/bahm2013.msi">www.clearcreeksolutions.info/ftp/public/downloads/BAHM2013/bahm2013.msi</a>.</p>
<p><b>Bay-Friendly Landscaping and Gardening</b></p>	<p>A holistic approach to gardening and landscaping that works in harmony with the natural conditions of the San Francisco Bay Watershed. Bay-Friendly practices foster soil health, conserve water and other valuable resources while reducing waste and preventing pollution.</p>
<p><b>Bay-Friendly Landscaping and Gardening Coalition/ ReScape California</b></p>	<p>The Bay-Friendly Landscaping &amp; Gardening Coalition, also known as ReScape California, is a non-profit organization that partners with local organizations, customizing best management practices for each region to establish sustainable landscape practices in California. See more at: <a href="http://rescapeca.org/">rescapeca.org/</a>.</p>
<p><b>Best Management Practice (BMP)</b></p>	<p>Any program, technology, process, siting criteria, operational method or measure, or engineered system, which when implemented prevents, controls, removes, or reduces pollution. Includes schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce water pollution. BMPs also include treatment requirements, operating procedures, and practices to control site runoff, spillage or leaks, litter or waste disposal, or drainage from raw material storage.</p>

**ALAMEDA COUNTYWIDE CLEAN WATER PROGRAM**

<p><b>Bioinfiltration Area</b></p>	<p>A type of low development treatment measure designed to have a surface ponding area that allows for evapotranspiration, and to filter water through 18 inches of engineered biotreatment soil. After the water filters through the engineered soil, it encounters a 12-inch layer of rock in which an underdrain is typically installed. If the underlying soils have a saturated hydraulic conductivity rate of 1.6" per hour or greater, then the C.3.d amount of runoff is treated by evapotranspiration and infiltration. If the soils have a lower hydraulic conductivity rate, then the bioinfiltration area treats stormwater with evapotranspiration, some infiltration, and the remaining amount of the C.3.d amount of runoff is filtered and released into the underdrain. The difference between a bioinfiltration area and a bioretention area is that the bioinfiltration area is never lined with an impermeable layer; whereas, a bioretention area may be lined or unlined.</p>
<p><b>Bioretention Area</b></p>	<p>A type of low development treatment measure designed to have a surface ponding area that allows for evapotranspiration, and to filter water through 18 inches of engineered biotreatment soil. After the water filters through the engineered soil, it encounters a 12-inch layer of rock in which an underdrain is typically installed. If the underlying soils have a saturated hydraulic conductivity rate of 1.6" per hour or greater, then the C.3.d amount of runoff is treated by evapotranspiration and infiltration. If the soils have a lower hydraulic conductivity rate, or if infiltration is prohibited and the bioretention area is lined with an impermeable layer, then the bioretention area treats stormwater with evapotranspiration, some or no infiltration, and the remaining amount of the C.3.d amount of runoff is filtered and released into the underdrain. The difference between a bioinfiltration area and a bioretention area is that the bioinfiltration area is never lined with an impermeable layer; whereas, a bioretention area may be lined or unlined.</p>
<p><b>Biotreatment</b></p>	<p>A type of low impact development treatment allowed under Provision C.3.c of the MRP. As required by Provision C.3.c.i(2)(vi), biotreatment systems shall be designed to have a surface area no smaller than what is required to accommodate a 5 inches/hour stormwater runoff surface loading rate and shall use biotreatment soil as specified in the biotreatment soil specifications approved by the Regional Water Board, or equivalent.</p>
<p><b>Buffer Strip or Zone</b></p>	<p>Strip of erosion-resistant vegetation over which stormwater runoff is directed.</p>
<p><b>C.3</b></p>	<p>Provision of the Municipal Regional Stormwater NPDES Permit (MRP) that requires each Discharger to control the flow of stormwater and stormwater pollutants from new development and redevelopment sites over which it has jurisdiction.</p>
<p><b>C.3 Regulated Projects</b></p>	<p>Development projects as defined by Provision C.3.b.ii of the MRP. This includes public and private projects that create and/or replace 10,000 square feet or more of impervious surface, and restaurants, retail gasoline outlets, auto service facilities, and uncovered parking lots (stand-alone or part of another use) that create and/or replace 5,000 square feet or more of impervious surface. Single family homes that are not part of a larger plan of development are specifically excluded.</p>

<b>C.3.d Amount of Runoff</b>	The amount of stormwater runoff from C.3 Regulated Projects that must receive stormwater treatment, as described by hydraulic sizing criteria in Provision C.3.d of the MRP.
<b>California Association of Stormwater Quality Agencies (CASQA)</b>	Publisher of the California Stormwater Best Management Practices Handbooks, available at <a href="http://www.casqa.org">www.casqa.org</a> . Successor to the Storm Water Quality Task Force (SWQTF).
<b>Clean Water Act (CWA)</b>	The Federal Water Pollution Prevention and Control Act, or Clean Water Act (33 U.S. Code 1251 <i>et seq.</i> ) is intended to control or eliminate surface water pollution and establishes the National Pollutant Discharge Elimination System, which regulates surface water discharges from municipal storm drains, publicly-owned treatment works and industrial discharges.
<b>Complete Application</b>	Applications that have been accepted by the Planning Department and have not received a letter within 30 calendar days stating that the application is incomplete (consistent with the Permit Streamlining Act). Where an application has not been accepted by the Planning Department and the applicant has received a letter within 30 days stating that the application is incomplete, the application will be deemed complete if the additional requested information is submitted to the satisfaction of the Planning Department.
<b>Conditions of Approval (COAs)</b>	Requirements the City may adopt for a project in connection with a discretionary action (e.g., adoption of an EIR or negative declaration or issuance of a use permit). COAs may include features to be incorporated into the final plans for the project and may also specify uses, activities, and operational measures that must be observed over the life of the project.
<b>Conduit/ Conveyance System/ Culvert</b>	Channels or pipes for collecting and directing the flow of water. Conduits and conveyance systems may be open channels, covered channels or pipes. Culverts are covered channels or large diameter pipes.
<b>Constructed Wetland</b>	Constructed detention basins that have a permanent pool of water throughout the year and capacity for temporary additional storage of runoff that is released via an outlet structure. They differ from wet ponds in that they are typically shallower and have greater vegetation coverage.
<b>Construction General Permit</b>	A NPDES permit issued by the State Water Resources Control Board (SWRCB) for the discharge of stormwater associated with construction activity from soil disturbance of one (1) acre or more. The current Construction General Permit was adopted by the SWRCB on September 2, 2009, and went into effect July 1, 2010.
<b>Design Storm</b>	A hypothetical rainstorm defined by rainfall intensities and durations.
<b>Detention</b>	The temporary storage of stormwater runoff in ponds, vaults, within berms, or in depressed areas to allow treatment by sedimentation and metered discharge of runoff at reduced peak flow rates. See Infiltration and retention.

**ALAMEDA COUNTYWIDE CLEAN WATER PROGRAM**

<b>Directly-Connected Impervious Area (DCIA)</b>	The area covered by a building, impermeable pavement, and/or other impervious surfaces, which drains directly into the storm drain without first flowing across permeable land area (e.g., turf buffers).
<b>Directly Discharging</b>	Outflow from a drainage conveyance system that is composed entirely or predominantly of flows from the subject property, development, subdivision, or industrial facility, and not commingled with flows from adjacent lands.
<b>Direct Infiltration</b>	Infiltration via methods or devices, such as dry wells or infiltration trenches, designed to bypass unsaturated surface soils and transmit runoff directly to groundwater.
<b>Discharge</b>	A release or flow of stormwater or other substance from a conveyance system or storage container.
<b>Discharger</b>	Any responsible party or site owner or operator within the Municipal Regional Stormwater NPDES Permit (MRP) Permittees' jurisdiction whose site discharges stormwater runoff, or a non-stormwater discharge.
<b>Drawdown Time</b>	The time required for a stormwater detention or infiltration BMP to drain and return to the dry-weather condition. For detention BMPs, drawdown time is a function of basin volume and outlet orifice size. For infiltration BMPs, drawdown time is a function of basin volume and infiltration rate.
<b>Dry Weather Flow</b>	Flows that occur during periods without rainfall. In a natural setting, dry weather flows result from precipitation that infiltrates into the soil and slowly moves through the soil to the stream channel. Dry weather flows in storm drains may result from human activities, such as over-irrigation.
<b>Dry Well</b>	Structure placed in an excavation or boring, or excavation filled with open-graded rock, that is designed to collect stormwater and infiltrate into the subsurface soil.
<b>Erosion</b>	The diminishing or wearing away of land due to wind or water. Often the eroded debris (silt or sediment) becomes a pollutant via stormwater runoff. Erosion occurs naturally, but can be intensified by land disturbing and grading activities such as farming, development, road building, or timber harvesting.
<b>Evapotranspiration</b>	Evaporating water into the air directly or through plant transpiration.
<b>Extended Detention Basin</b>	Constructed basins with drainage outlets that are designed to detain runoff from a water quality design storm for some minimum time (e.g., 48 hours) to allow settling of sediment and pollutants.
<b>Filter Fabric</b>	Geotextile of relatively small mesh or pore size that is used to: (a) allow water to pass through while keeping sediment out (permeable); or (b) prevent both runoff and sediment from passing through (impermeable).
<b>Flow-based Treatment Measures</b>	Stormwater treatment measures that treat pollutants from a moving stream of water through filtration, infiltration, and/or biological processes.

<b>Flow Duration</b>	Either a) the total hours that surface flow from a watershed or drainage area occurs at a specified magnitude in response to a long-term time history of rainfall inputs, or b) the cumulative percentage of total hours that flows exceed the specified magnitude (as used in the BAHM). The overall distribution of flow durations is then expressed by a histogram or cumulative distribution curve, showing flow durations for equal subdivisions of the full range of flow magnitudes occurring over time.
<b>Flow Duration Control</b>	An approach to mitigating development-caused hydromodification which involves developing continuous simulation models of runoff from both pre-project and post-project site conditions, comparing flow durations for a designated range of flows, and designing specialized detention and discharge structures to reduce excess post-project flow duration for flows in the designated range (See Chapter 7).
<b>Flow-Through Planter Box</b>	Structure designed to treat stormwater by intercepting rainfall and slowly draining it through filter media and out of planter.
<b>Grading</b>	The cutting and/or filling of the land surface to a desired shape or elevation.
<b>Green Roof/ Roof Garden</b>	Vegetated roof systems that retain and filter stormwater prior to drainage off building rooftops.
<b>Green Stormwater Infrastructure</b>	Infrastructure that uses vegetation, soils, and natural processes to manage water and create healthier urban environments. At the scale of a city or county, green stormwater infrastructure refers to the patchwork of natural areas that provides habitat, flood protection, cleaner air, and cleaner water. At the scale of a neighborhood or site, green stormwater infrastructure refers to stormwater management systems that mimic nature by soaking up and storing water – providing a sustainable system that slows runoff by dispersing it to vegetated areas, harvests and uses runoff, promotes infiltration and evapotranspiration, and uses bioretention and other low impact development practices to clean stormwater runoff.
<b>Groundwater</b>	Subsurface water that occurs in soils, and geologic formations that are fully saturated.
<b>Hazardous Waste</b>	By-products of human activities that can pose a substantial or potential hazard to human health or the environment when improperly managed. Possesses at least one of four characteristics (flammable, corrosivity, reactivity, or toxicity), or appears on special EPA lists.
<b>Head</b>	In hydraulics, energy represented as a difference in elevation. In slow-flowing open systems, the difference in water surface elevation, e.g., between an inlet and outlet.
<b>Heritage Tree</b>	An individual tree of any size or species given the ‘heritage tree’ designation as defined by the municipality’s tree ordinance or other section of the municipal code.
<b>High-Flow Bypass</b>	In stormwater treatment measures, a pipe, outlet, or other structure designed to convey flood flows directly to the storm drain systems without entering the treatment measure.

**ALAMEDA COUNTYWIDE CLEAN WATER PROGRAM**

<b>Hydrodynamic Separator</b>	A commonly used term for mechanical stormwater treatment systems that are designed as flow-through structures with a settling or separation unit to remove sediment and other pollutants that may settle to the bottom of the separation unit.
<b>Hydrograph</b>	Runoff flow rate plotted as a function of time.
<b>Hydromodification</b>	The modification of a stream's hydrograph, caused in general by increases in flows and durations that result when land is developed (e.g., made more impervious). The effects of hydromodification include, but are not limited to, increased bed and bank erosion, loss of habitat, increased sediment transport and deposition, and increased flooding.
<b>Hydrologic Soil Group</b>	Classification of soils by the Natural Resources Conservation Service (NCRS) into A, B, C, and D groups according to infiltration capacity.
<b>Imperviousness</b>	A term applied to surfaces – roads, sidewalks, rooftops, and parking lots – that prevent or inhibit rainfall from sinking into groundcover and groundwater.
<b>Impervious surface</b>	A surface covering or pavement of a developed parcel of land that prevents the land's natural ability to absorb and infiltrate rainfall/stormwater. Impervious surfaces include, but are not limited to, roof tops; walkways; patios; driveways; parking lots; storage areas; impervious concrete and asphalt; and any other continuous watertight pavement or covering. Landscaped soil and pervious pavement, including pavers with pervious openings and seams, underlain with pervious soil or pervious storage material, such as a gravel layer sufficient to hold at least the Provision C.3.d volume of rainfall runoff are not impervious surfaces. Open, uncovered retention/detention facilities are not considered impervious surfaces for purposes of determining whether a project is a Regulated Project under Provisions C.3.b and C.3.g. Open, uncovered retention/detention facilities shall be considered impervious surfaces for purposes of runoff modeling and meeting the Hydromodification standard.
<b>Indirect Infiltration</b>	Infiltration via facilities, such as swales and bioretention areas, that are expressly designed to hold runoff and allow it to percolate into surface soils. Runoff may reach groundwater indirectly or may be underdrained through subsurface pipes.
<b>Infiltration</b>	Seepage of runoff through the soil to mix with groundwater. See retention.
<b>Infiltration Devices</b>	Infiltration facilities that are deeper than they are wide and designed to infiltrate stormwater runoff into the subsurface and, as designed, bypass the natural groundwater protection afforded by surface soil. These devices include dry wells, injection wells and infiltration trenches (includes French drains).
<b>Infiltration Facilities</b>	A term that refers to both infiltration devices and measures.
<b>Infiltration Measures</b>	Infiltration facilities that are wider than they are deep (e.g., bioinfiltration, infiltration basins and shallow wide infiltration trenches and dry wells).

<b>Infiltration Trench</b>	Long narrow trench filled with permeable material (e.g., gravel), designed to store runoff and infiltrate through the bottom and sides into the subsurface soil.
<b>Inlet</b>	An entrance into a ditch, storm sewer, or other waterway.
<b>Integrated Management Practice (IMP)</b>	A stormwater treatment measure that meets both stormwater treatment and hydromodification management objectives.
<b>Integrated Pest Management (IPM)</b>	An approach to pest control that utilizes regular monitoring to determine if and when treatments are needed and employs physical, mechanical, cultural, biological, and educational tactics to keep pest numbers low enough to prevent unacceptable damage or annoyance. See Bay-Friendly Landscaping and Gardening.
<b>Low Impact Development</b>	A land planning and engineering design approach with a goal of reducing stormwater runoff and mimicking a site's predevelopment hydrology by minimizing disturbed areas and impervious cover and then infiltrating, storing, detaining, evapotranspiring, and/or biotreating stormwater runoff close to its source, or onsite.
<b>Low Impact Development (LID) Treatment</b>	Removal of pollutants from stormwater runoff using the following types of stormwater treatment measures: rainwater harvesting and use, infiltration, evapotranspiration, and biotreatment.
<b>Maintenance Plan</b>	A plan detailing operation and maintenance requirements for stormwater treatment measures and/or structural hydromodification measures incorporated into a project.
<b>Maximum Extent Practicable (MEP)</b>	A standard for implementation of stormwater management actions to reduce pollutants in stormwater. Clean Water Act (CWA) 402(p)(3)(B)(iii) requires that municipal stormwater permits "shall require controls to reduce the discharge of pollutants to the maximum extent practicable, including management practices, control techniques and system, design and engineering methods, and such other provisions as the Administrator or the State determines appropriate for the control of such pollutants." Also see State Board Order WQ 2000-11.
<b>Media Filter</b>	Two-chambered system that includes a pretreatment settling basin and a filter bed filled with sand or other absorptive filtering media.
<b>Municipal Regional Stormwater NPDES Permit (MRP)</b>	The Phase I municipal stormwater NPDES permit under which discharges are permitted from municipal separate storm sewer systems throughout Alameda County and other NPDES Phase I jurisdictions within the San Francisco Bay Region.
<b>New Development</b>	Land disturbing activities; structural development, including construction or installation of a building or structure, creation of impervious surfaces; and/or land subdivision.
<b>Non-Stormwater Discharge</b>	Any discharge to municipal separate storm drain that is not composed entirely of stormwater. Some types of non-stormwater discharges may be authorized by NPDES permits and others prohibited.



**ALAMEDA COUNTYWIDE CLEAN WATER PROGRAM**

<b>NPDES Permit</b>	An authorization, license, or equivalent control document issued by EPA or an approved State agency to implement the requirements of the National Pollutant Discharge Elimination System (NPDES) program. As part of the 1972 Clean Water Act, Congress established the NPDES permitting system to regulate the discharge of pollutants from municipal sewers and industries. The NPDES program was expanded in 1987 to incorporate permits for stormwater discharges as well. Regional Water Quality Control Boards issue stormwater NPDES Permits to local government agencies placing provisions on allowable discharges of municipal stormwater to waters of the state.
<b>Numeric Criteria</b>	Sizing requirements for stormwater treatment controls established in Provision C.3.d. of the MRP.
<b>Operation and Maintenance (O&amp;M)</b>	Refers to requirements in the stormwater NPDES permit to inspect stormwater treatment systems and hydromodification controls and implement preventative and corrective maintenance in perpetuity. See Chapter 8.
<b>Operational Source Control Measure</b>	Low technology, low cost activities, procedures, or management practices designed to prevent pollutants associated with site functions and activities from being discharged with stormwater runoff. Examples include good housekeeping practices, employee training, standard operating practices, inventory control measures, etc.
<b>Outfall/ Outlet</b>	The point where stormwater discharges from a pipe, channel, ditch, or other conveyance to a waterway.
<b>Percentile Rainfall Intensity</b>	A method of designing flow-based treatment controls that ranks long-term hourly rainfall intensities and selects the 85 <sup>th</sup> percentile value, and then doubles this value.
<b>Permeability</b>	A property of soil that enables water or air to move through it. Usually expressed in inches/hour or inches/day.
<b>Pervious Paving</b>	For the purposes of this document, pervious paving is defined as (but not limited to) any of the following types of paving or pavement systems: permeable interlocking concrete pavement (PICP), pervious or permeable concrete pavers, pervious grid pavements, pervious concrete, porous asphalt, turf block, grasscrete, and bricks and stones set on a gravel base with gravel joints. Pervious paving or pavement systems are designed to store and infiltrate rainfall at a rate equal to immediately surrounding unpaved, landscaped areas, or store and infiltrate the rainfall runoff volume described in provision C.3.d of the MRP.
<b>Pervious Surface</b>	Permeable hardscape or paved surface that allows surface runoff to infiltrate into surface soil (e.g., turf block, brick, natural stone, cobbles, gravel).
<b>Perviousness</b>	The permeability of a surface that can be penetrated by stormwater to infiltrate the underlying soils.
<b>Point of Compliance</b>	For design to meet Flow Duration Control requirements for hydromodification management, the point at which pre-project runoff is compared to post-project runoff, usually near the point where runoff leaves the project area.

**C.3 STORMWATER TECHNICAL GUIDANCE**

<b>Pollutant</b>	A substance introduced into the environment that adversely affects or potentially affects the usefulness of a resource.
<b>Post-Construction Stormwater Control</b>	See Stormwater Control.
<b>Precipitation</b>	Any form of rain or snow.
<b>Provision C.3</b>	A reference to the requirements in the MRP requiring each MRP Discharger to control the flow of stormwater and stormwater pollutants from new and redevelopment sites over which it has jurisdiction.
<b>Rational Method</b>	A method of calculating runoff flows based on rainfall intensity and the amount of runoff from the tributary area.
<b>Redevelopment</b>	Land-disturbing activity that results in the creation, addition, or replacement of exterior impervious surface area on a site on which some past development has occurred. The MRP excludes interior remodels and routine maintenance or repair, including roof or exterior surface replacement, pavement resurfacing, repaving and road pavement structural section rehabilitation within the existing footprint.
<b>Regional Water Quality Control Board, San Francisco Bay Area Water Board (RWQCB)</b>	One of nine California Regional Water Boards, the Regional Water Board for the San Francisco Bay Region is responsible for implementing pollution control provisions of the Clean Water Act and California Water Code within the area that drains to San Francisco Bay. Also referred to as Water Board.
<b>Retention</b>	The storage of stormwater to prevent it from leaving the development site; may be temporary or permanent.
<b>Runoff</b>	Water originating from rainfall and other sources (e.g., sprinkler irrigation) that is found in drainage facilities, creeks, streams, springs, seeps, ponds, lakes, wetlands, and shallow groundwater.
<b>Sedimentation</b>	The process of depositing soil particles, clays, sands, or other sediments that were picked up by runoff.
<b>Sediments</b>	Soil, sand and minerals washed from land into water, usually after rain.
<b>Self-Retaining Area</b>	A portion of a development site designed to retain the first one inch of rainfall (by ponding and infiltration and/or evapotranspiration) without producing stormwater runoff. Self-retaining areas must have at least a 2:1 ratio of contributing area to a self-retaining area and a 3" ponding depth. Self-retaining areas may include graded depressions with landscaping or pervious pavement. Areas that Contribute Runoff to Self-Retaining Areas are impervious or partially pervious areas that drain to self-retaining areas.
<b>Self-Treating Area</b>	A portion of a development site in which infiltration, evapotranspiration and other natural processes remove pollutants from stormwater. Self-treating areas may include conserved natural open areas, areas of landscaping, green roofs and pervious pavement. Self-treating areas treat only the rain falling on them and do not receive stormwater runoff from other areas.

**ALAMEDA COUNTYWIDE CLEAN WATER PROGRAM**

<b>Site Design Measures</b>	Site planning techniques to conserve natural spaces and/or limit the amount of impervious surface at new development and significant redevelopment projects in order to minimize runoff and the transport of pollutants in runoff.
<b>Source Control Measures</b>	Land use or site planning practices, or structural or nonstructural measures, that aim to prevent runoff pollution by reducing the potential for contact with rainfall runoff at the source of pollution. Source control measures minimize the contact between pollutants and urban runoff.
<b>Special Projects</b>	Certain types of smart growth, high density and transit oriented development projects that are allowed, under Provision C.3.e.ii of the MRP, to receive LID treatment reductions.
<b>Storm Drains</b>	Above and belowground structures for transporting stormwater to creeks or outfalls for flood control purposes.
<b>Storm Event</b>	A rainfall event that produces more than 0.1 inch of precipitation and is separated from the previous storm event by at least 72 hours of dry weather.
<b>Stormwater</b>	Stormwater runoff, snow-melt runoff, surface runoff, and drainage, excluding infiltration and irrigation tailwater.
<b>Stormwater Control</b>	A design feature of a development or redevelopment project, or a routinely-conducted activity that is intended to prevent, minimize or treat pollutants in stormwater, or to reduce erosive flows during the life of the project. Stormwater control is a term that collectively refers to site designs to promote water quality, source control measures, stormwater treatment measures, and hydromodification management measures. Also referred to as “post-construction stormwater control” or “post-construction stormwater measure.”
<b>Stormwater Pollution Prevention Plan (SWPPP)</b>	A plan providing for temporary measure to control sediment and other pollutants during construction.
<b>Stormwater Treatment Measure</b>	Any engineered system designed to remove pollutants from stormwater runoff by settling, filtration, biological degradation, plant uptake, media absorption/adsorption or other physical, biological, or chemical process. This includes landscape-based systems such as vegetated swales and bioretention units as well as proprietary systems. Sometimes called a treatment control, treatment control measure treatment system, or treatment control BMP.
<b>Total Project Cost</b>	Total project cost includes the construction (labor) and materials cost of the physical improvements proposed; however, it does not include land, transactions, financing, permitting, demolition, or off-site mitigation costs.
<b>Treatment</b>	Any method, technique, or process designed to remove pollutants and/or solids from polluted stormwater runoff, wastewater, or effluent.

**C.3 STORMWATER TECHNICAL GUIDANCE**

<b>Vector Control</b>	Any method to limit or eradicate vectors of vector born diseases, for which the pathogen (e.g. virus or parasite) is transmitted by a vector which can be mammals, birds or arthropods, especially insects, and more specifically mosquitoes. For the purposes of this document, vector control refers to mosquito control.
<b>Vegetated Buffer Strip</b>	Linear strips of vegetated surfaces that are designed to treat sheet runoff flow from adjacent surfaces.
<b>Volume-Based Stormwater Treatment Measures</b>	Stormwater treatment measures that detain stormwater for a certain period and treat primarily through settling and infiltration.
<b>Water Quality Inlet</b>	Systems that contain one or more chambers that promote sedimentation of coarse materials and separation of undissolved oil and grease from stormwater. Also referred to as oil/water separators.
<b>Water Quality Volume (WQV)</b>	For stormwater treatment measures that depend on detention to work, the volume of water that must be detained to achieve maximum extent practicable pollutant removal. This volume of water must be detained for a specified drawdown time.
<b>WEF Method</b>	A method for determining the required volume of treatment BMPs, recommended by the Water Environment Federation and American Society of Civil Engineers. Described in Urban Runoff Quality Management (WEF/ASCE, 1998).

*This page intentionally left blank*